

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/1237

Dated: 30.12.2024

**FIRE SAFETY CERTIFICATE**

Certified that **The Heritage School** located at **D-2, Vasant Kunj, New Delhi-110070** comprised of Basement, Ground plus Three upper floors owned/occupied by The Heritage School was issued FSC by this department vide letter No. F6/DFS/MS/School/2022/SZ/271 Dated 11-03-2022. The premises was re-inspected by officer concerned of this department on 17/12/2024 in presence of Dr. Sunita Swaraj (Principal) and observed that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class **"Educational Building" Group-B**, as above with effect from 30/12/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/12/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, The Heritage School located at D-2, Vasant Kunj, New Delhi-70
2. The Directorate of Education, Govt. of NCT of Delhi Old Secretariat, New Delhi-54

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL/NBC Part- IV
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.



PRINCIPAL  
THE HERITAGE SCHOOL  
D-2 Vasant Kunj,  
New Delhi-110 070