




**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG,
NEW DELHI-110016**



NO. DHO/SZ/MCD/2025/D- 648

Dated: 24/6/2025


SCHOOL HEALTH CERTIFICATE


It is certified that an inspection team headed by Sh. Ramtek, Assistant Public Health Inspector from Public Health Department, South Zone inspected the The Heritage School located at D-2, Vasant Kunj, New Delhi- 110070, on 23/06/2025

It was found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

If Building Department or any other Government Agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.


24/06/2025
Deputy Health Officer
South Zone


Deputy Health Officer
South Zone MCD

Copy to: -

- **The Principal**
The Heritage School
D-2, Vasant Kunj, New Delhi- 110070
- **Office Copy**



Nidha
PRINCIPAL
THE HERITAGE SCHOOL
D-2 Vasant Kunj,
New Delhi-110 070

Test Report

Quality Standard	Parameters as desired	
Issued to	-	Heritage School, Vasant Kunj, New Delhi
Kind attn.	-	Mr.
Analysis no.	-	26011602

Nature of Sample	-	Water Sample marked Drinking
Sample received on	-	16 th January 2026
Report Date	-	20 th January 2026
Analysis Dates	-	16 th January 2026 to 20 th January 2026
Sample receipt	-	Picked by Lab
Sample Packing	-	Sterilized and Pet Bottles

	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	05	IS 3025 Part 4	05	25
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	Absent	IS1622	Absent	Absent
	E.Coli	CFU/100ml	Absent	IS1622	Absent	Absent
Physical	pH	Unit Less	7.59	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25°C	334	IS 3025 Part 14	---	---
	Turbidity	NTU	0.60	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	181	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO ₃	mg/l	109	IS 3025 Part 23	200	600
	Total Hardness as CaCO ₃	mg/l	70.5	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	28.5	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	0.01	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20	--

Remarks: The no. of parameters tested is 14 only. The results indicate that the Quality of water may be considered to be within the desired limits for Drinking as per IS:10500 in regard to the parameters tested. The report is issued subject to the terms & conditions as mentioned overleaf.

Chemist

Authorized Signatory

Nidha

PRINCIPAL
THE HERITAGE SCHOOL
 D-2 Vasant Kunj,
 New Delhi-110 070



QUALITY LAB is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.

Office : 382, Vardhman Charve Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088

Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA

Exclusive representatives in India for Sens Aqua, Naeringshagen No. 7340. OPPDAL, Norway

Exclusive representatives in india for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking

Exclusive accelerarator partner in India for Mygreen Lab, 4653, Carmel Mountain Road, San Diego, California, USA

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DH0/S2/2026

Date: 02.04.2026

It is certified that an inspection team headed by Rajesh Kumar
Name of Officer with designation) from Assistant Sanitary officers (AS1) (Name of Department/Office) inspected the MCD, Greater Towns & Sanitation Name & Address of School on The Heritage School D-2 (Name of the School) Vasant Kunj and found that the The Heritage School D-2 (Name of the School) has safe the drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year

Signature with Seal : RAJESH KUMAR
Assistant Sanitary Inspector
DCMS Dept. MCD
Zone South
No. 156 Vasant Kunj
Name RAJESH KUMAR
Designation Assistant Sanitary Inspector

To
The Principal
The Heritage School
D-2 Vasant Kunj

(Name & Address of the institution)

